



BILL OF MATERIALS				
ITEM	QTY.	I.D.	DESCRIPTION	MGF - PART NUMBER
1	1		CHLORINATION ENCLOSURE	BEVCO 7521 (7521-F)
2	1		MAIN POWER DISCONNECT , FUSIBLE	GE TPF30R
3	2	FU1	15 AMP FUSES	GOULD TR15R
4	1		INTERIOR LIGHT	EPCCO EP15000
5	1	REC	DUPLEX RECPTACLE , 15 AMP	P&S 32321
6	1		DOOR SWITCH, 1 POLE	AB 802AF33P4
7	1		FAN EXHAUST FAN	BROAN 688
8	1		HEATER THERMOSTAT	ESAPCO CR2145
9	1		HEATER , 1250 WATT	FAHRENHEAT MMH1502T
10	1		FAN AUTO/MANUAL SWITCH	GE CR104PSG21B
11	1		TEST KIT HOLDER	TKHOLDER
12				
13				
14				
15				
16				
17				
18				
19				
20				

NOTE:
 △ ALL CONDUIT TO BE PVC U/L LISTED

			TITLE 7521, 7521F FIBERGLASS BUILDING STANDARD CONFIGURATION	
4	10/21/05	CHANGED SELECTOR SW. TO TOGGLE BOX	JLN	
3	07/18/05	UPDATED LIGHT IN PANEL	EWJ	DRW. BY RLS
2	4/12/04	CHANGED PIPING	JLN	SCALE NONE
1	4/23/03	CHANGED INCOMING TO 3 WIRE + GND	JLN	DATE 1-19-00
NO.	DATE	REVISION	BY	JOB
				DRAWING NUMBER SD-207