



### BILL OF MATERIALS

ITEM	QTY.	I.D.	DESCRIPTION	MGF - PART NUMBER
1	1		CHLORINATION ENCLOSURE	BEVCO 7523 (7523F)
2	1		MAIN POWER DISCONNECT , FUSIBLE	GE TPF30R
3	2	FU1	15 AMP FUSES	GE TR15R
4	2		INTERIOR LIGHT	EPCO EP15000
5	2	REC	DUPLEX RECPTACLE , 15 AMP	P&S 32321
6	2		DOOR SWITCH, 1 POLE	AB 802AF33P4
7	1	FAN	EXHAUST FAN	BROAN 688
8	1		HEATER THERMOSTAT	ESAPCO TH15
9	1		HEATER , 1250 WATT	FAHRENHEAT MHH1502T
10	1		FAN/LIGHT AUTO/MANUAL SWITCH	LEVITON 1451-2
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				

NOTE:

△ ALL CONDUIT TO BE PVC U/L LISTED CARLON

			TITLE 7523, 7523F FIBERGLASS BUILDING STANDARD CONFIGURATION	
2	07/08/09	ADDED 10.5" BOTTLES FOR FITMENT	MAP	DRW. BY SFS
1	4/23/03	CHANGED INCOMING TO 3 WIRE + GND	JLN	SCALE NONE
NO.	DATE	REVISION	BY	DATE 8-17-95
				DRAWING NUMBER
				SD-211